



Pihak Berkuasa Air Negeri Sarawak

Certificate of Approval for Water Supply Products

The *State Water Authority of Sarawak* hereby gives approval for this water supply product to be used in the Sarawak Water Supply Authority areas, under the powers vested in Part III clause 9 of the Water Supply Regulations 1995:

Name of water supply product	Swing Check Valve	Model:
Brand	TEK	
Class & size	See schedule on reverse page	
Standard	BS EN 12334 : 2001	
Manufacturer/Supplier	TEK Valve (M) Sdn. Bhd. PT 22432, Lot Asal 6535, Sungai Puloh Batu 51/2, Jalan Kapar, 42450 Klang, Selangor	

This approval is given subject to the following conditions:

- i. The State Water Authority of Sarawak reserves the right to withdraw this approval at any time and shall not be obliged to give any reason whatsoever.
- ii. The specifications for the water supply product shall not differ from that originally submitted in the application for approval.
- iii. There are to be no unsuitabilities in the use of this product.
- iv. This certificate of approval shall not be used for any advertisement purpose. However a copy can be used as evidence of approval only.
- v. This certificate of approval shall become invalid upon expiry of SPAN Supplier Registration Certification, SIRIM Licence or IKRAM Bhd Certification or other internationally recognized certification.
- vi. This certificate of approval shall be valid from 28 MAR 2018 to 27 MAR 2020.

.....
 Pihak Berkuasa Air Negeri
 Sarawak

Date of issue : 28 MAR 2018

Schedule

Tek Valve (M) Sdn. Bhd.

No	Product	Description	Class & Size
1	Swing Check Valve (ANSI/AWWA C 512 : 2007)	Double Flanged PN 16	50, 80, 100, 150, 200, 250, 300, 350, 400, 450, 500 & 600 Obturator Seat = Copper Alloy
		Double Flanged PN 16	DN50, DN80, DN100, DN150, DN200, DN250, DN300, DN350, DN400, DN450, DN500 & DN600 OBTURATOR SEAT = EPDM