



State Water Authority
Certificate of Approval for Water Supply Product

The State Water Authority of Sarawak hereby gives approval for this water supply product to be used in the Water Supply Authority areas within Sarawak, under the powers vested in Part III Regulation 9 of the Water Supply Regulations 1995:

Name of Water Supply Product: **VALVE(GATE VALVE)**

Name & Address of Certificate Holder: **TEK VALVE (M) SDN BHD**
PT 22432 LOT ASAL 6535 JALAN
SUNGGAI PULOH, BATU 5 1/2 , JALAN
KAPAR

Type: **Fitting**

Nature of Business Entity of Certificate: **Supplier**

Brand: **TEK**

Name & Address of Manufacturer: **QUANZHOU YONGCHUN FENGJI**
WATER WARM EQUIPMENT AND
SUPPLIES CO.LTD.
QUANZHOU YONGCHUN FENGJI
WATER WARM EQUIPMENT AND
SUPPLIES CO.LTD. TAN HUA SHAN
INDUSTRIES AREA, YONGCHUN
COUNTY, 362600 QUANZHOU, FUJIAN,
CHINA

Standard: **BS 5163-1:2004**

Class & Size: **See schedule on the reverse page**

Validity Period: **20/07/2023** to **30/05/2024**

Name & Address of Principal: **TEK VALVE (M) SDN BHD**
PT 22432 LOT ASAL 6535 JALAN
SUNGGAI PULOH BATU 5/2,JALAN
KAPAR .42200 KLANG .SELANGOR

Date of Issue: **20/07/2023**

This approval is given subject to the following:

- i. The State Water Authority of Sarawak reserves the right to withdraw this approval at anytime and shall not be obliged to give any reason whatsoever.
- ii. The specifications for the water supply products shall not differ from that originally submitted in the application for approval.
- iii. There should not be any unsuitability in the use of this product.
- iv. This certificate of approval shall not be used for any advertisement purpose. However, a copy can be used as evidence of approval only.
- v. This certificate of approval shall become invalid upon expiry of SPAN Product Certificate Registration or SIRIM Licence or IKRAM Bhd Certification or other internationally recognized certification of the product, whichever is earlier.



Digitally Signed by JAFRI BIN LIAS

State Water Authority

Schedule

COMPANY NAME: **TEK VALVE (M) SDN BHD**

PRODUCT: **VALVE(GATE VALVE)**

VALIDITY PERIOD: **20/07/2023 - 30/05/2024**

CERTIFICATE NUMBER: **SWA/F/0692**

Model	Series	Description
DOUBLE FLANGE	PN 16	NOMINAL SIZE : DN50, DN65, DN80, DN125, DN100, DN150, DN200, DN250, DN300, DN350, DN400, DN450, DN500, DN600

End of Page



State Water Authority
Certificate of Approval for Water Supply Product

The State Water Authority of Sarawak hereby gives approval for this water supply product to be used in the Water Supply Authority areas within Sarawak, under the powers vested in Part III Regulation 9 of the Water Supply Regulations 1995:

<p>Name of Water Supply Product: VALVE(GATE VALVE)</p> <p>Type: Fitting</p> <p>Brand: TEK</p> <p>Standard: BS EN 1171 :2002</p> <p>Class & Size: See schedule on the reverse page</p> <p>Validity Period: <u>20/07/2023</u> to <u>30/05/2024</u></p> <p>Date of Issue: 20/07/2023</p>	<p>Name & Address of Certificate Holder: TEK VALVE (M) SDN BHD PT 22432 LOT ASAL 6535 JALAN SUNGAI PULOH, BATU 5 1/2 , JALAN KAPAR</p> <p>Nature of Business Entity of Certificate: Supplier</p> <p>Name & Address of Manufacturer: QUANZHOU YONGCHUN FENGJI WATER WARM EQUIPMENT AND SUPPLIES CO.LTD. QUANZHOU YONGCHUN FENGJI WATER WARM EQUIPMENT AND SUPPLIES CO.LTD. TAN HUA SHAN INDUSTRIAL AREA, YONGCHUN COUNTY 362600 QUANZHOU FUJIAN, CHINA.</p> <p>Name & Address of Principal: TEK VALVE (M) SDN BHD PT 22432 LOT ASAL 6535 JALAN SUNGAI PULOH BATU 5 1/2,JALAN KAPAR,42200 KLANG SELANGOR</p>
---	--

This approval is given subject to the following:

- i. The State Water Authority of Sarawak reserves the right to withdraw this approval at anytime and shall not be obliged to give any reason whatsoever.
- ii. The specifications for the water supply products shall not differ from that originally submitted in the application for approval.
- iii. There should not be any unsuitability in the use of this product.
- iv. This certificate of approval shall not be used for any advertisement purpose. However, a copy can be used as evidence of approval only.
- v. This certificate of approval shall become invalid upon expiry of SPAN Product Certificate Registration or SIRIM Licence or IKRAM Bhd Certification or other internationally recognized certification of the product, whichever is earlier.



Digitally Signed by JAFRI BIN LIAS

State Water Authority

Schedule

COMPANY NAME: **TEK VALVE (M) SDN BHD**

PRODUCT: **VALVE(GATE VALVE)**

VALIDITY PERIOD: **20/07/2023 - 30/05/2024**

CERTIFICATE NUMBER: **SWA/F/0691**

Model	Series	Description
Cast Iron Gate Valve	PN16, Maximum Service Temperat ure = 70 Degree Cel	BODY END TYPE = DOUBLE FLANGE BODYBONNET MATERIAL = EN GJS 500-7 ; STEM = SS431 (NON RISING) ; FACE TO FACE = SERIES 3 ; TRIM = RESILIENT SEAT (RES) SIZE : DN700 , DN800 , DN900

End of Page



State Water Authority
Certificate of Approval for Water Supply Product

The State Water Authority of Sarawak hereby gives approval for this water supply product to be used in the Water Supply Authority areas within Sarawak, under the powers vested in Part III Regulation 9 of the Water Supply Regulations 1995:

<p>Name of Water Supply Product: VALVE(GATE VALVE)</p> <p>Type: Fitting</p> <p>Brand: TEK</p> <p>Standard: EN 1074-2:2004</p> <p>Class & Size: See schedule on the reverse page</p> <p>Validity Period: <u>20/07/2023</u> to <u>18/04/2024</u></p> <p>Date of Issue: 20/07/2023</p>	<p>Name & Address of Certificate Holder: TEK VALVE (M) SDN BHD PT 22432 LOT ASAL 6535 JALAN SUNGAI PULOH, BATU 5 1/2 , JALAN KAPAR</p> <p>Nature of Business Entity of Certificate: Supplier</p> <p>Name & Address of Manufacturer: QUANZHOU YONGCHUN FENGJI WATER WARM EQUIPMENT AND SUPPLIES CO.LTD. QUANZHOU YONGCHUN FENGJI WATER-WARM EQUIPMENT AND SUPPLIES CO.LTD,TAN HUA SHAN INDUSTRIAL AREA, YONGCHUN COUNTY 362600 QUANZHOU FUJIAN, CHINA.</p> <p>Name & Address of Principal: TEK VALVE (M) SDN BHD PT 22432 LOT ASAL 6535 JALAN SUNGAI PULOH BATU 5 1/2 JALAN KAPAR,42200 KLANG.SELANGOR.</p>
---	--

This approval is given subject to the following:

- i. The State Water Authority of Sarawak reserves the right to withdraw this approval at anytime and shall not be obliged to give any reason whatsoever.
- ii. The specifications for the water supply products shall not differ from that originally submitted in the application for approval.
- iii. There should not be any unsuitability in the use of this product.
- iv. This certificate of approval shall not be used for any advertisement purpose. However, a copy can be used as evidence of approval only.
- v. This certificate of approval shall become invalid upon expiry of SPAN Product Certificate Registration or SIRIM Licence or IKRAM Bhd Certification or other internationally recognized certification of the product, whichever is earlier.



Digitally Signed by JAFRI BIN LIAS

State Water Authority

Schedule

COMPANY NAME: **TEK VALVE (M) SDN BHD**

PRODUCT: **VALVE(GATE VALVE)**

VALIDITY PERIOD: **20/07/2023 - 18/04/2024**

CERTIFICATE NUMBER: **SWA/F/0694**

Model	Series	Description
DOUBLE FLANGE; LG2 COPPER ALLOY FACE	PN 16	NOMINAL SIZE : DN1000, DN1100, DN1200, DN1250, DN1300
TYPE OF BODY= DOUBLE FLANGE ; TRIM = RES ; STEM = SUS 431S29 (NONRISING) ; BODY = SG (EN GJS 500-7)	PN 16	NOMINAL SIZE : DN50, DN65, DN80, DN100, DN125, DN150, DN200, DN250, DN300, DN350, DN400, DN450, DN500, DN600, DN700, DN800, DN900, DN1000, DN1100, DN1200, DN1400, DN1600

End of Page
